



NÁRODNÍ AKREDITAČNÍ ORGÁN

EA MLA Signatory
Český institut pro akreditaci, o.p.s.
Olšanská 54/3, 130 00 Praha 3

issues

according to section 16 of Act No. 22/1997 Coll., on technical requirements for products, as amended

CERTIFICATE OF ACCREDITATION

No. 190/2017

TRIGON PLUS s.r.o.
with registered office Zápvní 93, 251 01 Čestlice, Company Registration No. 46350110

to the Testing Laboratory No. 1679
TRIGON PLUS, Testing Laboratory

Scope of accreditation:

Measurement of equipment with air cleanliness control – measurement of air cleanliness, number of particles, flow velocity in laminar flow hoods, and non destructive inspection of air filter equipment to the extent as specified in the appendix to this Certificate.

This Certificate of Accreditation is a proof of Accreditation issued on the basis of assessment of fulfillment of the accreditation criteria in accordance with

ČSN EN ISO/IEC 17025:2005

In its activities performed within the scope and for the period of validity of this Certificate, the Body is entitled to refer to this Certificate, provided that the accreditation is not suspended and the Body meets the specified accreditation requirements in accordance with the relevant regulations applicable to the activity of an accredited Conformity Assessment Body.

This Certificate of Accreditation replaces, to the full extent, Certificate No.: 117/2015 of 18February 2015, or any administrative acts building upon it.

The Certificate of Accreditation is valid until: **18. 2. 2018**

Prague: 24. 3. 2017



Jiří Růžička
Director
Czech Accreditation Institute
Public Service Company

The Appendix is an integral part of
Certificate of Accreditation No. 190/2017 of 24/03/2017

Accredited entity according to ČSN EN ISO/IEC 17025:2005:

TRIGON PLUS s.r.o.
TRIGON PLUS, Testing Laboratory
Západní 93, 251 01 Čestlice

*The Laboratory is qualified to update standards identifying the test procedures.
The Laboratory provides expert opinions and interprets test results.*

Tests:

Ordinal number ¹⁾	Test procedure/method name	Test procedure/method identification	Tested object
1. *	Determination of mean flow velocity and flow uniformity	ZL – PP-01 (ČSN EN 12469, ČSN EN ISO 14644-3)	Clean rooms and equipment with air and gas cleanliness control
2. *	Enumeration of aerosol particles in air and gas	ZL – PP-02 (ČSN EN 14644-1, ČSN EN 14644-3)	Clean rooms and equipment with air and gas cleanliness control
3.*	Non destructive inspection of filters by a laser particle counter	ZL – PP-03 (ČSN EN 14644-3)	High performance aerosol filter cartridges
4.*	Non destructive inspection of filters by photometry	ZL – PP-07 (ČSN EN 14644-3)	High performance aerosol filter cartridges

¹⁾ Asterisk at the ordinal number identifies the tests, which the Laboratory is qualified to carry out outside the permanent laboratory premises.

Explanations:

ZL-PP-Test Procedure TRIGON PLUS, Testing Laboratory

